

## Tube Rupture – Vapor

Heat Exchanger Tube Rupture Vapor			
<b>Equipment Data:</b>			
Equipment Tag Number:	EqTag	Equipment Type:	EqType
Drawing:	Drawing	MAWP:	MAWP psig
Description:	Description	MAWT:	MAWT F
<b>Scenario Input Data:</b>		<b>Scenario Output Data:</b>	
Upstream Pressure:	P1 psig	Upstream Density:	rho1 lb/ft3
Upstream Pressure Basis:	P1Basis	Upstream Z:	Z1
Upstream Temperature:	T1 F	Upstream K:	K1
Dewpoint Vapor:	<input checked="" type="checkbox"/>	Orifice (Tubesheet) Flow C:	FlowC
Set Pressure:	SetP psig	Orifice Flow Choked:	OrificeChoked
Allowable Overpressure:	OverP	Orifice Choke Pressure:	OrificeChokeP psig
Constant Back Pressure:	P3 psig	Orifice Mass Flowrate:	OrificeFlow lb/hr
Required Relief Rate Units:	RateUnit	Tube Flow Choked:	TubeChoked
Tube OD:	TubeOD	Tube Exit Pressure:	TubeChokeP psig
Tube BWG:	TubeBWG	Tube Mass Flowrate:	TubeFlow lb/hr
Tube Inner Diameter:	TubeID in	Required Mass Rate:	RequiredRateMass lb/hr
Tube Equivalent Length:	TubeL ft	Required Rate Std. Vol.:	RequiredRateMM MMSCFD
Pipe Roughness:	PipeRoughness ft	Required Air Rate:	RequiredRateAir scfh air
Number of Segments:	Segments	Relief Mass Flux:	Flux2 lb/sec/ft2
<input checked="" type="checkbox"/> Use Thermo	<input checked="" type="checkbox"/> Friction Only		
Thermo Package:	ThermoPackage		
StreamID			
Open Stream	New Stream		
Relief Device Kd:	Kd		
Nozzle Sizing:	Sizing		
Outlet Pipe Sizing:	OutPipeSizing		
Calculate		Preview	Print
Close			
Notes:	Notes		

## Equipment Data:

The six fields under Equipment Data are specified on the Overpressure Scenario Form.

## Input Data:

The form fields for inputs are blue and organized under the Scenario Input column. They are described below:

**P1** – Pressure upstream of restriction orifice. From most to least conservative: MAWP, PSV Set, PSHH, Max Operating

**P1Basis** – Description for choice of P1. PSV-100 Set Pressure, PSHH Setpoint, etc.

**T1** – Temperature at inlet to pipe for PT Flash Only. Calculated for PQ (Dewpoint) Flash.

**Dewpoint** – If true, a PQ Flash is performed with quality = 1.0. Otherwise superheated with PT Flash.

**SetP** – PSV set pressure used to determine relief pressure.

**OverP** – Allowable overpressure typically 10% used to determine relief pressure.

**P3** – Constant back pressure when PSV is closed.

**TubeOD** – Tube outer diameter (used along with **TubeBWG** to get **TubeID**)

**TubeBWG** – Tube Birmingham Wire Gauge (used along with **TubeOD** to get **TubeID**)

**TubeID** – Tube inner diameter (calculated if **TubeOD** and **TubeBWG** entered, otherwise must be input)

**TubeL** – Tube equivalent length

**PipeRoughness** – Roughness used to quantify tube friction factor (default = 0.0018 in for carbon steel)

**Segments** – Number of segments to be analyzed. 10 segments with 20' tubes will be analyzed 2' at a time.

**UseThermo** – If false, additional property inputs are required.

**ThermoPackage** – Thermo package used for properties. VMG (Symmetry) packages or REFPROP 10.0 from NIST

**StreamID** – The stream to be used for properties. A new stream can be added here. See [Stream Definition Form](#).

**Kd** – Manufacturer's certified vapor Kd or 0.975 for API STD 520 default.

**Sizing** – PSV sizing method: API 520 Vapor or Numerical Integration (recommended when  $Z \leq 0.8$ ).

**OutPipeSizing** – Outlet pressure drop method: Adiabatic, Omega Method or Numerical Integration.

## Calculation Method:

This form supports flow of a vapor through a tube rupture in a shell and tube heat exchanger. The tube break is assumed to occur at the tube sheet such that fluid will flow directly through the tubesheet which is treated as an orifice and through the tube which is quantified based on pipe flow. The orifice flow calculation is identical to the Vapor Orifice Flow calculation and the pipe flow calculation is identical to the Vapor Pipe Flow. Reference those individual forms for the detailed calculation method for each.

## Scenario Output Data:

The form fields for scenario-specific outputs are organized under the Scenario Output column. These are described below:

rho1 - Upstream density in lb/ft<sup>3</sup> typically from thermo engine.

Z1 - Upstream compressibility typically from thermo engine.

K1 - Upstream ideal  $C_p/C_v$  typically from thermo engine.

FlowC – Orifice discharge coefficient corrected for the velocity of approach.

OrificeChoked – Applicable to flow through the tubesheet, Yes for critical flow, no for subcritical flow

OrificeChokeP – Applicable to flow through the tubesheet. Calculated choke pressure or downstream pressure if not choked

OrificeFlow – Calculated flow through the tubesheet

TubeChoked – Applicable to flow through the tube, Yes for critical flow, no for subcritical flow

TubeChokeP – Applicable to flow through the tube. Calculated choke pressure or downstream pressure if not choked

TubeFlow – Calculated flow through the tube

RequiredRateMass – Sum of OrificeFlow and TubeFlow in lb/hr.

RequiredRateMM – Required rate in MMSCFD

RequiredRateAir – Required rate converted to scfh air

Flux2 –  $\text{RequiredRateMass} \cdot \text{RequiredArea} \cdot 144 / 3600$

### Scenario Calculation Results:

The form fields for overall scenario results are organized in the Scenario Calculation Results Section. These outputs are typical of most of the scenario calculations and are detailed under Typical Scenario Calculation Results.

### QA/QC Benchmarks:

As described under the Calculation Method Section, the tube rupture calculation is the sum of orifice flow and pipe flow both of which have been benchmarked individually. As such, the Tube Rupture Numerical Integration was benchmarked against these two individual sheets to ensure consistency. As the following reports show the two flows calculated by the Tube Rupture Numerical Integration method are essentially identical to the individual flows calculated by the Orifice Numerical Integration and Pipe Flow Numerical Integration forms.

# Tube Rupture Vapor

## HX-2000 Tube Rupture



### Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

### Scenario Description:

The MAWP of the high pressure side of HX-2000 is 350 psig, therefore a tube rupture could result in overpressure. The required relief rate was based on the residue gas composition at 800 psig and 120 F. The tubes were selected as 1" BWG 24 to closely match 1" Sch 80 from the pipe flow benchmark case.

### Scenario Calculation Results:

Required Rate:	38,877.5	lb/hr	Device Choke Pressure:	83.6	psig
Actual Capacity:	19,755.4	lb/hr	Outlet Temperature:	80.3	F
Required Area:	3.632	in2	Outlet Mass Quality:	1.000	
Actual Area:	1.838	in2	Outlet Density:	0.043	lb/ft3
Relief Pressure:	165.0	psig	Outlet Ideal Cp/Cv:	1.296	
Relief Temperature:	89.4	F	Outlet Viscosity:	0.011	cP
Relief MW:	16.74		Inlet Non-Recoverble dP:	1.4	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	1.0	% Set
Relief Density:	0.522	lb/ft3	Built-Up Back Pressure:	11.0	psig
Relief SG:	0.577		Built-Up Back P % Set:	7.4	% Set
Relief Z:	0.979		Total Back Pressure:	11.0	psig
Relief Ideal Cp/Cv:	1.293		Total Back P % Set:	7.4	% Set
Relief Viscosity:	0.011	cP	Reaction Force:	257	lbf

# Tube Rupture Vapor

## HX-2000 Tube Rupture



### Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

### Scenario Input Data:

Upstream Pressure:	<input type="text" value="800"/>	psig
Upstream Pressure Basis:	<input type="text" value="MAWP"/>	
Upstream Temperature:	<input type="text" value="120"/>	F
Dewpoint Vapor:	<input type="checkbox"/>	
Set Pressure:	<input type="text" value="150"/>	psig
Allowable Overpressure:	<input type="text" value="10.0%"/>	
Constant Back Pressure:	<input type="text" value="0"/>	psig
Required Relief Rate Units:	<input type="text" value="lb/hr"/>	
Tube Inner Diameter:	<input type="text" value="0.954"/>	in
Tube Equivalent Length:	<input type="text" value="20"/>	ft
Pipe Roughness:	<input type="text" value="0.0018"/>	ft
Use Thermo <input checked="" type="checkbox"/>	Friction Only <input type="checkbox"/>	
Thermo Package:	<input type="text" value="REFPROP 10.0"/>	
Relief Device Kd:	<input type="text" value="0.975"/>	
Nozzle Sizing:	<input type="text" value="API 520 Vapor"/>	
Outlet Pipe Sizing:	<input type="text" value="Isothermal"/>	

### Scenario Output Data:

Upstream Density:	<input type="text" value="2.364"/>	lb/ft3
Upstream Z:	<input type="text" value="0.927"/>	
Upstream K:	<input type="text" value="1.286"/>	
Orifice (Tubesheet) Flow C:	<input type="text" value="0.6"/>	
Orifice Flow Choked:	<input type="text" value="Yes"/>	
Orifice Choke Pressure:	<input type="text" value="432"/>	psig
Orifice Mass Flowrate:	<input type="text" value="21298.4"/>	lb/hr
Tube Flow Choked:	<input type="text" value="Yes"/>	
Tube Exit Pressure:	<input type="text" value="221.2"/>	psig
Tube Mass Flowrate:	<input type="text" value="17579.1"/>	lb/hr
Required Mass Rate:	<input type="text" value="38877.5"/>	lb/hr
Required Rate Std. Vol.:	<input type="text" value="21.20"/>	MMSCFD
Required Air Rate:	<input type="text" value="688297.5"/>	scfh air
Relief Mass Flux:	<input type="text" value="428.2"/>	lb/sec/ft2

Notes: Current relief valve is undersized for the tube rupture scenario.

Tube Rupture Vapor  
HX-2000 Tube Rupture



Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

Relief Stream Composition:

Stream Description:     Residue Gas

Component	Mole Fraction
methane	0.9577
ethane	0.0320
propane	0.0008
butane	
isobutane	
pentane	
isopentane	
hexane	
heptane	
octane	
nonane	
decane	
carbon dioxide	0.0070
nitrogen	0.0025
methanol	
water	



## Pipe Flow Vapor

### 1" Drain Valve Open



#### Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

#### Scenario Description:

The maximum upstream pressure is 800 psig as dictated by the set point of PSHH-1000. As such, a failure open of PCV-1000 could result in overpressure and the required relief rate was based on the recovery residue gas composition at 800 psig and 120 F upstream of control valve with the relief pressure of 165 psig downstream. Flow coefficients were based on a 1" Fisher D4 with 1/2" m-form trim and the control valve is installed in a 2" line.

#### Scenario Calculation Results:

Required Rate:	17,836.4	lb/hr	Device Choke Pressure:	98.5	psig
Actual Capacity:	19,675.0	lb/hr	Outlet Temperature:	75.9	F
Required Area:	1.66	in2	Outlet Mass Quality:	1.000	
Actual Area:	1.838	in2	Outlet Density:	0.043	lb/ft3
Relief Pressure:	165.0	psig	Outlet Ideal Cp/Cv:	1.288	
Relief Temperature:	86.2	F	Outlet Viscosity:	0.011	cP
Relief MW:	16.74		Inlet Non-Recoverble dP:	1.4	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	1.0	% Set
Relief Density:	0.528	lb/ft3	Built-Up Back Pressure:	11.2	psig
Relief SG:	0.577		Built-Up Back P % Set:	7.5	% Set
Relief Z:	0.973		Total Back Pressure:	11.2	psig
Relief Ideal Cp/Cv:	1.286		Total Back P % Set:	7.5	% Set
Relief Viscosity:	0.011	cP	Reaction Force:	259	lbf

# Pipe Flow Vapor

## 1" Drain Valve Open



### Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

### Input Data:

Upstream Pressure:	<input type="text" value="800"/> psig
Upstream Pressure Basis:	<input type="text" value="MAWP"/>
Upstream Temperature:	<input type="text" value="120"/> F
Dewpoint Vapor:	<input type="checkbox"/>
Set Pressure:	<input type="text" value="150"/> psig
Allowable Overpressure:	<input type="text" value="10.00%"/>
Constant Back Pressure:	<input type="text" value="0"/> psig
Required Relief Rate Units:	<input type="text" value="lb/hr"/>
Friction Losses Only:	<input type="checkbox"/>
Pipe NPS:	<input type="text" value="1"/>
Pipe Schedule:	<input type="text" value="80"/>
Pipe Inner Diameter:	<input type="text" value="0.957"/> in
Pipe Equivalent Length:	<input type="text" value="20"/> ft
Pipe Roughness:	<input type="text" value="0.0018"/> ft
Use Thermo	<input checked="" type="checkbox"/>
Thermo Package:	<input type="text" value="Advanced_Peng-Robinson"/>
Relief Device Kd:	<input type="text" value="0.975"/>
Nozzle Sizing:	<input type="text" value="API 520 Vapor"/>
Outlet Pipe Sizing:	<input type="text" value="Isothermal"/>

Notes:

### Output Data:

Upstream Density:	<input type="text" value="2.404"/> lb/ft3
Upstream Z:	<input type="text" value="0.912"/>
Upstream Ideal Cp/Cv:	<input type="text" value="1.279"/>
Moody Friction Factor:	<input type="text" value="0.0231"/> ft
Choked:	<input type="text" value="Yes"/>
Exit Pressure:	<input type="text" value="222.5"/>
Required Mass Rate:	<input type="text" value="17,836.4"/> psig
Required Rate Std Vol:	<input type="text" value="9.7"/> lb/hr
Required Air Rate:	<input type="text" value="314,853.7"/> MMSCFD
Relief Mass Flux:	<input type="text" value="429.8"/> scfh air
	lb/sec/ft2



# Pipe Flow Vapor

## 1" Drain Valve Open



### Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

### Relief Stream Composition:

#### Stream Description: Residue Gas

Component	Mole Fraction
methane	0.9577
ethane	0.0320
propane	0.0008
butane	
isobutane	
pentane	
isopentane	
hexane	
heptane	
octane	
nonane	
decane	
carbon dioxide	0.0070
nitrogen	0.0025
methanol	
water	
	0.0070
	0.0025

## Vapor Restriction Orifice

### HX Tube Rupture RO



#### Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

#### Scenario Description:

This calculation is the flow through the tubesheet, which is based on orifice flow, for comparison to the HX-2000 tube rupture case.

#### Scenario Results Summary:

Required Rate:	21,424	lb/hr	Device Choke Pressure:	83.8	psig
Actual Capacity:	19,755	lb/hr	Outlet Temperature:	75.9	F
Required Area:	1.993	in2	Outlet Mass Quality:	1.000	
Actual Area:	1.838	in2	Outlet Density:	0.043	lb/ft3
Relief Pressure:	165.0	psig	Outlet Ideal Cp/Cv:	1.288	
Relief Temperature:	86.2	F	Outlet Viscosity:	0.011	cP
Relief MW:	16.74		Inlet Non-Recoverable dP:	1.4	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	1.0	% Set
Relief Density:	0.528	lb/ft3	Built-Up Back Pressure:	11.0	psig
Relief SG:	0.577		Built-Up Back P % Set:	7.4	% Set
Relief Z:	0.973		Total Back Pressure:	11.0	psig
Relief Ideal Cp/Cv:	1.286		Total Back P % Set:	7.4	% Set
Relief Viscosity:	0.011	cP	Reaction Force:	257	lbf

#### Atmospheric Dispersion Screening (Constant Back Pressure = 0 and Hydrocarbons Only):

Tail Pipe Exit Diameter:		in		Actual	Reseat
Reset % Capacity:	0.0	%	Exit RE:		
Exit Minimum RE:			Exit Velocity:		fps
Horizontal Distance (x):	0	ft	Exit/Wind Velocity:	0.0	0.0
Sonic Velocity:		fps	Minimum Exit Velocity:	0.0	0.0
Exit Quality Acceptable:	<input type="checkbox"/>		Horizontal Distance (x):		ft
Lighter than Air:	<input type="checkbox"/>				
Flammable::	<input type="checkbox"/>				
Toxic:	<input type="checkbox"/>				
Dispersion Screening Pass:					

## Vapor Restriction Orifice

### HX Tube Rupture RO



#### Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

#### Scenario Input Data:

RO Tag Number:	HX-2000 Tubesheet
Gas Type:	Residue Gas
Upstream Pressure:	800 psig
Upstream Pressure Basis:	MAWP
Upstream Temperature:	120 F
Dewpoint Vapor:	<input type="checkbox"/>
Set Pressure:	150 psig
Allowable Overpressure:	10.0%
Constant Back Pressure:	0.0 psig
Pipe Inner Diameter:	10.02 in
Orifice Inner Diameter:	0.954 in
Thermodynamics Enabled:	<input checked="" type="checkbox"/>
Thermo Package:	Advanced_Peng-Robinson
Relief Device Kd:	0.975
Nozzle Sizing:	API 520 Vapor
Outlet Pipe Sizing:	Adiabatic

#### Scenario Output Data:

Beta:	0.095
Orifice Flow C:	0.6
Discharge Cd:	0.6
Upstream Z:	0.912
Upstream Density:	2.404 lb/ft3
Choked:	Yes
Choke Pressure:	433 psig
Mach Number:	1
Required Mass Rate.:	21423.6 lb/hr
Required Rate Std Vol:	11.7 MMSCFD
Required Air Rate:	378176.8 scfh air
Required Mass Flux:	429.9 lb/sec/ft2

Notes:

## Vapor Restriction Orifice

### HX Tube Rupture RO



#### Equipment Data:

Equipment Tag:	V-1000	Type:	Pressure Vessel
Drawing:	PID-1000	MAWP:	150 psig
Description:	Slug Catcher	MAWT:	250 F

#### Relief Stream Composition:

##### Stream Description:     Residue Gas

Component	Mole Fraction
methane	0.9577
ethane	0.0320
propane	0.0008
butane	
isobutane	
pentane	
isopentane	
hexane	
heptane	
octane	
nonane	
decane	
carbon dioxide	0.0070
nitrogen	0.0025
methanol	
water	