



GAS PLANT XYZ

PSV-1100

V-1100, INLET SEPARATOR

SCENARIO SUMMARY	2-6
LCV-3400 FAILURE OPEN GAS BLOWBY	7-10
EXTERNAL FIRE LIQUID CONDENSATE VAPORIZATION	11-13
V-4100/4200 1" MANUAL DRAIN OPEN	14-16
F-3300/3301 OR V-4100/4200 LCV BYPASS OPEN GAS-BLOWBY	17-19
COMPRESSOR 3RD STAGE SUCTION SCRUBBER GAS-BLOWBY	20-22
LCV-3400 BYPASS OPEN GAS BLOWBY	23-25
EXTERNAL FIRE WATER VAPORIZATION CALCULATION	26-28
LCV-4100/4200 FAILURE OPEN GAS BLOWBY	29-32
LCV-3300/3301 FAILURE OPEN GAS BLOWBY	33-36
PSV-1100 DESIGN CASE DETAILED SIZING	37-38
PSV-1100 DATASHEET	39
PSV-1100 TEST REPORT	40
PSV-1100 VENDOR CERTIFICATION	41
PSV-1100 INLET AND OUTLET PIPING	42
V-1100 NAMEPLATE	43
RELEVANT PIDS	44-51

P.E. STATE OF COLORADO #42086



Scenario Summary



Equipment Tag:	V-1100	Relief Valve Tag:	PSV-1100	
Equipment Description:	Inlet Separator	Relief Valve Type/Size:	Conventional	4" x M x 6"
MAWP/MAWT/MDMT:	720 psig @ 120 / -20 F	Relief Valve Orifice Area:	4.08 in2	
Drawing Number:	PID-1100	Relief Valve Set Pressure:	250 psig	

Recommendations:

Notes:

Scenario / Credible	Description	Constraint	P1 / P2	Req. Rate / Area	In/Out/Total dP (Rated Capacity)
LCV-3400 Failure Open	<p>The After Separator sends liquids to the Inlet Separator and has a design pressure of 1,440 psig and the maximum pressure is limited to 1,250 psig by the compressor 3rd stage discharge PSHH set points. As such, overpressure could occur in the event the level control valve were to fail open or bypass is inadvertently opened with subsequent gas blowby. Per field verification, LCV-3400 is a 2" Kimray 2200SMT PO with 1" linear trim. Flow coefficients were obtained from vendor literature. The upstream conditions were based on 1,250 psig and 120 F. This case represents what is currently present in the field.</p> <p>Note the liquid inventory in the After Scrubber is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.</p>	LCV-3400	1250	61,605.3 lb/hr	2.9 psi 1.2 % Set
Basis Case		2" Kimray 2200SMT PO, 1" Linear Trim	313.5	3.117 in2	22.1 psi 8.8 % Set
		Cv = 21.0, Xt = 0.77			22.1 psig 8.8 % Set
V-1100 External Fire HC Liquid	<p>The Inlet Separator may contain hydrocarbon liquids that condense out of the inlet stream. As such, overpressure could occur in the event of an external fire due to vaporization of the liquid. As the simulation predicts only water condensation, the hydrocarbon liquid composition was estimated by dropping the temperature to about 40 F and using the resulting hydrocarbon liquid composition at the relief pressure of 344.9 psig. The liquid level of 80% was based on the location of LSHH-1101 as estimated in the field.</p>	LSHH-1101		55,551.1 lb/hr	2.5 psi 1.0 % Set
Credible				2.003 in2	24.5 psi 9.8 % Set
		Level = 80%			24.5 psig 9.8 % Set

Scenario / Credible	Description	Constraint	P1 / P2	Req. Rate / Area	In/Out/Total dP (Rated Capacity)
V-4100/4200 Drain Valve Inadvertently Opened	<p>The Contactor scrubber section also has a 1" ball valve that can drain liquid to the Inlet Separator. As described for the failure open of the LCV case, inadvertent opening of the drain valve could result in overpressure due to gas blowby. The required relief rate was evaluated using the same conditions as the control valves and 19.6 equivalent feet of 1" Sch 80 pipe as determined from the 3D model (1 entrance, 6.5' pipe, 1 ball valve, 1 swing check valve, 2 tee through runs).</p> <p>Note the liquid inventory in the contactors is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.</p>	V-4100/4200 Drain	1250	34,660.5 lb/hr	2.8 psi 1.1 % Set
Credible		1" Ball Valve	313.5	1.801 in2	21.3 psi 8.5 % Set
		ID = 0.957", Leq = 19.6'			21.3 psig 8.5 % Set
LCV-3300/3301/4100/4200 Bypass Open	<p>In a similar manner as the control valves, inadvertent opening of the 1" globe valve bypass around LCV-3300, 3301 and 4100 could result in overpressure. The required relief rate was based on the normal gas composition at 1,250 psig and 120 F. The globe valve Cv was based on a regular port globe valve (Crane) and an Xt = 1.0 was assumed.</p>	F-3300 and V-4100/4200 LCV Bypasses	1250	22,507.3 lb/hr	2.9 psi 1.2 % Set
Credible		1" RP Globe Valve	313.5	1.139 in2	22.1 psi 8.8 % Set
		Cv = 6.8, Xt = 1			22.1 psig 8.8 % Set
Gas Blowby from Compressor Scrubbers	<p>The Inlet Separator receives liquids from the 2nd Stage and 3rd Stage Compressor Suction Scrubbers. The maximum pressures in the 2nd Stage Suction Scrubbers are limited to 200 psig (1st Stage Discharge PSHH set point), while the maximum pressure in the 3rd Stage Suction Scrubbers are limited to 500 psig (2nd Stage Discharge PSHH set point). As such, In the event that a liquid level control valve or manual bypass valve on one of the 3rd Stage Suction Scrubbers fails or is inadvertently opened overpressure of the Inlet Separator could occur due to gas blowby. All of the liquid level dump stations consist of a 1" LCV and a 1" manual bypass ball valve. As the 1" bypass represents the worst case, the required relief rate was conservatively based on the flow through 10' of 1" Sch 160 pipe (scrubbers are physically about 15' apart). The upstream conditions were taken as 500 psig at 120 F with the downstream relief pressure of 313.5 psig.</p> <p>Note the liquid inventory in the Scrubbers is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.</p>	3rd Scrubber LCV or Bypass	500	10,342.5 lb/hr	2.8 psi 1.1 % Set
Credible		1" Sch 160 Piping	313.5	0.565 in2	21.6 psi 8.6 % Set
		Leq = 10', ID = 0.815"			21.6 psig 8.6 % Set

Scenario / Credible	Description	Constraint	P1 / P2	Req. Rate / Area	In/Out/Total dP (Rated Capacity)	
LCV-3400 Bypass Failure Open	<p>The After Separator sends liquids to the Inlet Separator and has a design pressure of 1,440 psig and the maximum pressure is limited to 1,250 psig by the compressor 3rd stage discharge PSHH set points. As such, overpressure could occur in the event the bypass is inadvertently opened with subsequent gas blowby. Per field verification, the relief requirement is limited by RO-3400 with 3/8" ID. The upstream conditions were based on 1,250 psig and 120 F.</p> <p>Note the liquid inventory in the After Scrubber is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.</p>	LCV-3400 or Bypass	1250	6,425.9 lb/hr	2.8 psi	1.1 % Set
Credible		RO-3400	313.5	0.334 in2	21.3 psi	8.5 % Set
		ID = 3/8"			21.3 psig	8.5 % Set
V-1100 External Fire Water	<p>The Inlet Separator may contain water that condenses out of the inlet stream. As such, overpressure could occur in the event of an external fire due to vaporization of the water. The fluid properties were based on the properties of pure water at the relief pressure of 344.9 psig (trace dissolved hydrocarbons were conservatively removed). The liquid level of 80% was based on the location of LSHH-1101 as estimated in the field.</p>	LSHH-1101		4,756.1 lb/hr	3.3 psi	1.3 % Set
Credible				0.306 in2	25.6 psi	10.2 % Set
		Level = 80%			25.6 psig	10.2 % Set
LCV-4100/4200 Failure Open	<p>The Contactor scrubber section sends liquids to the Inlet Separator and has a design pressure of 1,440 psig and the maximum pressure is limited to 1,250 psig by the compressor 3rd stage discharge PSHH set points. As such, overpressure could occur in the event any of the level control valves were to fail open with subsequent gas blowby. The required relief rate was based on the normal gas composition at 1,250 psig and 120 F. Per field verification, LCV-4100 is a 1" Kimray 1400SMT PO with 1/4" linear trim and flow coefficients were obtained from vendor literature.</p> <p>Note the liquid inventory in the 42" ID contactor is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.</p>	LCV-4100/4200	1250	4,824.9 lb/hr	2.8 psi	1.1 % Set
Credible		1" Kimray 1400SMT PO, 1/4" Linear Trim	313.5	0.255 in2	21.6 psi	8.6 % Set
		Cv = 2.17, Cf = 0.78			21.6 psig	8.6 % Set

Scenario / Credible	Description	Constraint	P1 / P2	Req. Rate / Area	In/Out/Total dP (Rated Capacity)	
LCV-3300/1 Failure Open	<p>The Inlet Filter Coalescer sends liquids from both chambers to the Inlet Separator and has a design pressure of 1,440 psig and the maximum pressure is limited to 1,250 psig by the compressor 3rd stage discharge PSHH set points. As such, overpressure could occur in the event either of the level control valves were to fail open with subsequent gas blowby. The required relief rate was based on the normal gas composition at 1,250 psig and 120 F. Per field verification, LCV-3300 and 3301 are both 1" Kimray 1400SMT PO with 3/8" linear trim and flow coefficients were obtained from vendor literature.</p> <p>Note the liquid inventory in the Coalescer is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.</p>	LCV-3300/3301	1250	4,886.9 lb/hr	2.9 psi	1.2 % Set
Credible		1" Kimray 1400SMT PO, 1/4" Linear Trim	313.5	0.248 in2	22.1 psi	8.8 % Set
		Cv = 2.17, Cf = 0.78			22.1 psig	8.8 % Set
VRU Drain Pump	<p>Liquids from the two VRU Compressors are pumped from the suction scrubber to the Inlet separator by a positive displacement pump with a rated flow of 5 gpm. Overfilling from this intermittent source is considered not credible, therefore the pumps do not present a potential source of overpressure.</p>					
Not Credible						
BPV-4130/4230 Failure Open	<p>Vapors from the TEG Flash Separators are routed to the Inlet Separator via BPV-4130 and BPV-4230. As the maximum pressure in the TEG Flash Separator is limited to 125 psig by the design pressure and associated relief valve, a failure open of this control valve is not a credible scenario.</p>					
Not Credible						
Blocked Outlet - Pipeline Inlet	<p>The maximum inlet pipeline pressure cannot exceed 215 psig. Therefore, overpressure of the Inlet Separator due to a blocked outlet is not an overpressure concern.</p>					
Not Credible						
External Fire Vapor Expansion	<p>The Inlet Separator may be free of liquids in which case overpressure could occur due to expansion of the vapor during an external fire. However, based on the maximum suction pressure of 60 psig (compressor 1st stage suction PSHH set point), the temperature would have to exceed the maximum wall temperature of 1,100 F to reach the relief pressure of 344.9 psig. As such, a thermal failure would be expected prior to overpressure and the relief valve does not provide protection against this scenario.</p>					
Not Credible						

Scenario / Credible	Description	Constraint	P1 / P2	Req. Rate / Area	In/Out/Total dP (Rated Capacity)
Instrument Air Failure Not Credible	In the event of an instrument air failure, the inlet from pipeline will be shutdown by the fail closed ESD-0100 as well as PCV-1000/1001. In addition, the main plant recycle control valve (PCV-2000) along with other high pressure dump valves that feed back to suction are all fail closed. Finally, the suction header, discharge header and fuel gas header will be depressured by fail open blowdown valves.				
Electric Power Failure Not Credible	An electric power failure does not represent an overpressure concern. The compressors are expected to shutdown and ultimately instrument air will be lost. See Instrument Air Failure.				
PCV-2000 Failure Open Not Credible	PSV-2000 which is present on the suction header and set at 215 psig provides protection for a failure open of PCV-2000 (Plant Recycle), therefore this scenario does not require consideration for this relief valve.				
PCV-1100 or PCV-1101 Failure Open Not Credible	Although the Inlet Separator (V-1100) has relief provided via PSV-1100 at 285 psig, the maximum inlet pipeline pressure cannot exceed 215 psig. Therefore, a failure open of either pipeline inlet pressure control valves does not represent a potential overpressure scenario.				

Vapor Control Valve Failure: LCV-3400

LCV-3400 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

The After Separator sends liquids to the Inlet Separator and has a design pressure of 1,440 psig and the maximum pressure is limited to 1,250 psig by the compressor 3rd stage discharge PSHH set points. As such, overpressure could occur in the event the level control valve were to fail open or bypass is inadvertently opened with subsequent gas blowby. Per field verification, LCV-3400 is a 2" Kimray 2200SMT PO with 1" linear trim. Flow coefficients were obtained from vendor literature. The upstream conditions were based on 1,250 psig and 120 F. This case represents what is currently present in the field.

Note the liquid inventory in the After Scrubber is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.

Scenario Calculation Results:

Required Rate:	61,605.3	lb/hr	Device Choke Pressure:	167.9	psig
Actual Capacity:	80,613.7	lb/hr	Outlet Temperature:	22.3	F
Required Area:	3.117	in2	Outlet Mass Quality:	1.000	
Actual Area:	4.08	in2	Outlet Density:	0.062	lb/ft3
Relief Pressure:	313.5	psig	Outlet Ideal Cp/Cv:	1.249	
Relief Temperature:	56.1	F	Outlet Viscosity:	0.009	cP
Relief MW:	21.56		Inlet Non-Recoverble dP:	2.9	psi
Relief Mass Quality:	0.987		Inlet dP % Set:	1.0	% Set
Relief Density:	1.422	lb/ft3	Built-Up Back Pressure:	22.1	psig
Relief SG:	0.743		Built-Up Back P % Set:	7.8	% Set
Relief Z:	0.899		Total Back Pressure:	22.1	psig
Relief Ideal Cp/Cv:	1.242		Total Back P % Set:	7.8	% Set
Relief Viscosity:	0.010	cP	Reaction Force:	1393	lbf

Vapor Control Valve Failure: LCV-3400

LCV-3400 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Input Data:

Control Valve Tag:	LCV-3400
Gas Type:	Inlet Gas
Upstream Pressure:	1250 psig
Upstream Pressure Basis:	3rd Stage Discharge PSHH
Upstream Temperature:	120 F
Dewpoint Vapor:	<input type="checkbox"/>
Set Pressure:	285 psig
Allowable Overpressure:	10.0%
Constant Back Pressure:	0 psig
Required Relief Rate Units:	lb/hr
Sizing Method	IEC
Cv:	21
Xt (Cf for Kimray):	0.77
C1:	
Cg:	
Control Valve ID:	1.939 in
Inlet Pipe ID:	1.939 in
Outlet Pipe ID:	1.939 in
Additional Flow:	0.0 lb/hr
Use Thermo	<input checked="" type="checkbox"/>
Thermo Package:	Advanced_Peng-Robinson
Relief Device Kd:	0.818
Nozzle Sizing:	API 520 Vapor
Outlet Pipe Sizing:	Adiabatic

Scenario Output Data:

Fk:	0.88
K1 Inlet Piping Resistance:	0
K2 Outlet Piping Resistance:	0
K1 Inlet Piping Bernoulli:	0
K2 Outlet Piping Bernoulli:	0
Fp:	1
dP/P1 Actual:	0.740
dP/P1 Critical:	0.674
Y:	0.667
Upstream Density:	5.673 lb/ft3
Upstream Z:	0.772
Upstream Ideal Cp/Cv:	1.226
Control Valve Flow:	61,605.3 lb/hr
Required Mass Rate:	61,605.3 lb/hr
Required Rate Std Vol:	26.0 MMSCFD
Required Air Rate:	931,447.0 scfh air
Relief Mass Flux:	790.5 lb/sec/ft2

Notes:

Vapor Control Valve Failure: LCV-3400

LCV-3400 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Composition:

Stream Description: Sigma Dry Gas

Component	Mole Fraction
carbon dioxide	0.0048
nitrogen	0.0155
methane	0.7553
ethane	0.1281
propane	0.0624
isobutane	0.0053
butane	0.0184
isopentane	0.0031
pentane	0.0042
hexane	0.0015
heptane	0.0007
octane	0.0007
nonane	0.0000
decane	0.0000
methanol	0.0000
water	0.0000
triethylene glycol	0.0000

LCV-3400



External Fire Boiling Liquid API STD 521

V-1100 External Fire HC Liquid



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

The Inlet Separator may contain hydrocarbon liquids that condense out of the inlet stream. As such, overpressure could occur in the event of an external fire due to vaporization of the liquid. As the simulation predicts only water condensation, the hydrocarbon liquid composition was estimated by dropping the temperature to about 40 F and using the resulting hydrocarbon liquid composition at the relief pressure of 344.9 psig. The liquid level of 80% was based on the location of LSHH-1101 as estimated in the field.

Scenario Calculation Results:

Required Rate:	55551.1	lb/hr	Device Choke Pressure:	172.4	psig
Actual Capacity:	113181.6	lb/hr	Outlet Temperature:	319.1	F
Required Area:	2.003	in2	Outlet Mass Quality:	1.000	
Actual Area:	4.080	in2	Outlet Density:	0.107	lb/ft3
Relief Pressure:	344.9	psig	Outlet Ideal Cp/Cv:	1.065	
Relief Temperature:	355.9	F	Outlet Viscosity:	0.010	cP
Relief MW:	59.94		Inlet Non-Recoverble dP:	2.5	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.9	% Set
Relief Density:	3.24	lb/ft3	Built-Up Back Pressure:	24.5	psig
Relief SG:	2.067		Built-Up Back P % Set:	8.6	% Set
Relief Z:	0.76		Total Back Pressure:	24.5	psig
Relief Ideal Cp/Cv:	1.06		Total Back P % Set:	8.6	% Set
Relief Viscosity:	0.011	cP			

External Fire Boiling Liquid API STD 521

V-1100 External Fire HC Liquid



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Input Data:

Length:	<input type="text" value="20"/>	ft
Diameter:	<input type="text" value="66"/>	in
Orientation:	<input type="text" value="Horizontal"/>	
Head Type:	<input type="text" value="2:1 Ellipsoidal"/>	
Level Basis:	<input type="text" value="LSHH-1101"/>	
Additional Wetted Area:	<input type="text" value="9.8"/>	ft2
Level:	<input type="text" value="80%"/>	
Bottom Elevation:	<input type="text" value="4"/>	ft
Area Exponent:	<input type="text" value="0.82"/>	
Adequate Drainage	<input type="checkbox"/>	
Insulation Factor:	<input type="text" value="1"/>	
Start Mass % Vapor:	<input type="text" value="0.00%"/>	
Finish Mass % Vapor:	<input type="text" value="5.00%"/>	
Remove Sensible Heat:	<input checked="" type="checkbox"/>	Correct for Densities: <input type="checkbox"/>
Set Pressure:	<input type="text" value="285"/>	psig
Allowable Overpressure:	<input type="text" value="21.0%"/>	
Constant Back Pressure:	<input type="text" value="0"/>	psig
Use Thermodynamics:	<input checked="" type="checkbox"/>	
Thermo Package:	<input type="text" value="Advanced_Peng-Robinson"/>	
Relief Device Kd:	<input type="text" value="0.818"/>	
Nozzle Sizing:	<input type="text" value="API Numerical Integration Vapor"/>	
Outlet Pipe Sizing:	<input type="text" value="Adiabatic"/>	

Notes:

Additional area accounts for boot which was estimated to be 18" OD x 2' S/S.

Scenario Output Data:

Wetted Area:	<input type="text" value="305.8"/>	ft2
Fire Heat Input:	<input type="text" value="3.77"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="600.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="532.2"/>	Btu/lb
Latent Heat:	<input type="text" value="67.8"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="320.6"/>	F
Temp. at Start Quality:	<input type="text" value="320.7"/>	F
Cp at Start Quality:	<input type="text" value="0.737"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.773"/>	Btu/lb/F
Liquid Density:	<input type="text" value="32.10"/>	lb/ft3
Required Mass Rate:	<input type="text" value="55551.1"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="8.44"/>	MMSCFD
Required Air Rate:	<input type="text" value="633378.9"/>	scfh air
Relief Mass Flux:	<input type="text" value="1109.6"/>	lb/sec/ft2

V-1100 External Fire HC Liquid



Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Description: V-1100 Fire HC Vapor

[illegible]

Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

The Contactor scrubber section also has a 1" ball valve that can drain liquid to the Inlet Separator. As described for the failure open of the LCV case, inadvertent opening of the drain valve could result in overpressure due to gas blowby. The required relief rate was evaluated using the same conditions as the control valves and 19.6 equivalent feet of 1" Sch 80 pipe as determined from the 3D model (1 entrance, 6.5' pipe, 1 ball valve, 1 swing check valve, 2 tee through runs).

Note the liquid inventory in the contactors is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.

Scenario Results Summary:

Required Rate:	34660.5	lb/hr	Device Choke Pressure:	125.4	psig
Actual Capacity:	78893	lb/hr	Outlet Temperature:	22.3	F
Required Area:	1.801	in2	Outlet Mass Quality:	1.000	
Actual Area:	4.08	in2	Outlet Density:	0.062	lb/ft3
Relief Pressure:	313.5	psig	Outlet Ideal Cp/Cv:	1.249	
Relief Temperature:	56.1	F	Outlet Viscosity:	0.010	cP
Relief Mass Quality:	0.987		Inlet Non-Recoverble dP:	2.8	psi
Relief Density:	1.42	lb/ft3	Inlet dP % Set:	1.0	% Set
Relief MW:	21.56		Built-Up Back Pressure:	21.3	psig
Relief Viscosity:	0.010	cP	Built-Up Back P % Set:	7.5	% Set
			Total Back Pressure:	21.3	psig
			Total Back P % Set:	7.5	% Set
			Reaction Force:	1052	lbf

Pipe Flow Numerical Integration



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Calculations:

Input Data:

Upstream Pressure:	1250	psig
Upstream Pressure Basis:	3rd Stage Discharge PSHH	
Flash Type:	PT	
Upstream Mass Quality:	1.000	
Upstream Temperature:	120.0	F
Set Pressure:	285	psig
Allowable Overpressure:	10.00%	
Constant Back Pressure:	0	psig
Pipe Nominal Pipe Size:	1"	
Pipe Nominal Pipe Schedule:	80	
Pipe Inner Diameter:	0.957	in
Pipe Equiv. Length:	19.6	ft
Pipe Roughness:	0.0018	in
Number of Increments:	10	
Relief Device Liquid Kd:	0.707	
Relief Device Vapor Kd:	0.818	
Thermo Package:	Advanced_Peng-Robinson	
Nozzle Sizing:	API Numerical Integration	
Outlet Pipe Sizing:	Isothermal	

Notes:

Output Data:

Upstream Density:	5.67	lb/ft3
Upstream Z:	0.772	
Upstream Ideal Cp/Cv:	1.226	
Upstream Viscosity:	0.011	cP
Choked:	Yes	
Exit Pressure:	379.6	psig
Relief Device Kd:	0.817	
Relief Mass Flux:	769.8	lb/sec/ft2
Fanning Friction Factor:	0.006	

Pipe Flow Numerical Integration



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Composition:

Stream Description: Sigma Dry Gas

Component	Mole Fraction
carbon dioxide	0.0048
nitrogen	0.0155
methane	0.7553
ethane	0.1281
propane	0.0624
isobutane	0.0053
butane	0.0184
isopentane	0.0031
pentane	0.0042
hexane	0.0015
heptane	0.0007
octane	0.0007
nonane	0.0000
decane	0.0000
methanol	0.0000
water	0.0000
triethylene glycol	0.0000

Vapor Control Valve Failure: LCV-3300/01/4100/200

LCV-3300/3301/4100/4200 Bypass Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

In a similar manner as the control valves, inadvertent opening of the 1" globe valve bypass around LCV-3300, 3301 and 4100 could result in overpressure. The required relief rate was based on the normal gas composition at 1,250 psig and 120 F. The globe valve Cv was based on a regular port globe valve (Crane) and an Xt = 1.0 was assumed.

Scenario Calculation Results:

Required Rate:	22,507.3	lb/hr	Device Choke Pressure:	167.9	psig
Actual Capacity:	80,613.7	lb/hr	Outlet Temperature:	22.3	F
Required Area:	1.139	in2	Outlet Mass Quality:	1.000	
Actual Area:	4.08	in2	Outlet Density:	0.062	lb/ft3
Relief Pressure:	313.5	psig	Outlet Ideal Cp/Cv:	1.249	
Relief Temperature:	56.1	F	Outlet Viscosity:	0.009	cP
Relief MW:	21.56		Inlet Non-Recoverble dP:	2.9	psi
Relief Mass Quality:	0.987		Inlet dP % Set:	1.0	% Set
Relief Density:	1.422	lb/ft3	Built-Up Back Pressure:	22.1	psig
Relief SG:	0.743		Built-Up Back P % Set:	7.8	% Set
Relief Z:	0.899		Total Back Pressure:	22.1	psig
Relief Ideal Cp/Cv:	1.242		Total Back P % Set:	7.8	% Set
Relief Viscosity:	0.010	cP	Reaction Force:	1393	lbf

Vapor Control Valve Failure: LCV-3300/01/4100/200

LCV-3300/3301/4100/4200 Bypass Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Input Data:

Control Valve Tag:	LCV-3300/01/4100/200 Bypass
Gas Type:	Inlet Gas
Upstream Pressure:	1250 psig
Upstream Pressure Basis:	3rd Stage Discharge PSHH
Upstream Temperature:	120 F
Dewpoint Vapor:	<input type="checkbox"/>
Set Pressure:	285 psig
Allowable Overpressure:	10.0%
Constant Back Pressure:	0 psig
Required Relief Rate Units:	lb/hr
Sizing Method	IEC
Cv:	6.8
Xt (Cf for Kimray):	1
C1:	
Cg:	
Control Valve ID:	0.957 in
Inlet Pipe ID:	0.957 in
Outlet Pipe ID:	0.957 in
Additional Flow:	0.0 lb/hr
Use Thermo	<input checked="" type="checkbox"/>
Thermo Package:	Advanced_Peng-Robinson
Relief Device Kd:	0.818
Nozzle Sizing:	API 520 Vapor
Outlet Pipe Sizing:	Adiabatic

Scenario Output Data:

Fk:	0.88
K1 Inlet Piping Resistance:	0
K2 Outlet Piping Resistance:	0
K1 Inlet Piping Bernoulli:	0
K2 Outlet Piping Bernoulli:	0
Fp:	1
dP/P1 Actual:	0.740
dP/P1 Critical:	0.876
Y:	0.718
Upstream Density:	5.673 lb/ft3
Upstream Z:	0.772
Upstream Ideal Cp/Cv:	1.226
Control Valve Flow:	22,507.3 lb/hr
Required Mass Rate:	22,507.3 lb/hr
Required Rate Std Vol:	9.5 MMSCFD
Required Air Rate:	340,301.2 scfh air
Relief Mass Flux:	790.5 lb/sec/ft2

Notes:

Vapor Control Valve Failure: LCV-3300/01/4100/200

LCV-3300/3301/4100/4200 Bypass Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Composition:

Stream Description: Sigma Dry Gas

Component	Mole Fraction
carbon dioxide	0.0048
nitrogen	0.0155
methane	0.7553
ethane	0.1281
propane	0.0624
isobutane	0.0053
butane	0.0184
isopentane	0.0031
pentane	0.0042
hexane	0.0015
heptane	0.0007
octane	0.0007
nonane	0.0000
decane	0.0000
methanol	0.0000
water	0.0000
triethylene glycol	0.0000

Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

The Inlet Separator receives liquids from the 2nd Stage and 3rd Stage Compressor Suction Scrubbers. The maximum pressures in the 2nd Stage Suction Scrubbers are limited to 200 psig (1st Stage Discharge PSHH set point), while the maximum pressure in the 3rd Stage Suction Scrubbers are limited to 500 psig (2nd Stage Discharge PSHH set point). As such, In the event that a liquid level control valve or manual bypass valve on one of the 3rd Stage Suction Scrubbers fails or is inadvertently opened overpressure of the Inlet Separator could occur due to gas blowby. All of the liquid level dump stations consist of a 1" LCV and a 1" manual bypass ball valve. As the 1" bypass represents the worst case, the required relief rate was conservatively based on the flow through 10' of 1" Sch 160 pipe (scrubbers are physically about 15' apart). The upstream conditions were taken as 500 psig at 120 F with the downstream relief pressure of 313.5 psig.

Note the liquid inventory in the Scrubbers is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.

Scenario Results Summary:

Required Rate:	10342.5	lb/hr	Device Choke Pressure:	125.4	psig
Actual Capacity:	74921.7	lb/hr	Outlet Temperature:	82.5	F
Required Area:	0.565	in2	Outlet Mass Quality:	1.000	
Actual Area:	4.08	in2	Outlet Density:	0.055	lb/ft3
Relief Pressure:	313.5	psig	Outlet Ideal Cp/Cv:	1.235	
Relief Temperature:	106.9	F	Outlet Viscosity:	0.011	cP
Relief Mass Quality:	1.000		Inlet Non-Recoverble dP:	2.8	psi
Relief Density:	1.26	lb/ft3	Inlet dP % Set:	1.0	% Set
Relief MW:	21.56		Built-Up Back Pressure:	21.6	psig
Relief Viscosity:	0.011	cP	Built-Up Back P % Set:	7.6	% Set
			Total Back Pressure:	21.6	psig
			Total Back P % Set:	7.6	% Set
			Reaction Force:	1061	lbf

Pipe Flow Numerical Integration



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Calculations:

Input Data:

Upstream Pressure:	500	psig
Upstream Pressure Basis:	2nd Stage Discharge PSHH	
Flash Type:	PT	
Upstream Mass Quality:	1.000	
Upstream Temperature:	120.0	F
Set Pressure:	285	psig
Allowable Overpressure:	10.00%	
Constant Back Pressure:	0	psig
Pipe Nominal Pipe Size:	1"	
Pipe Nominal Pipe Schedule:	160	
Pipe Inner Diameter:	0.815	in
Pipe Equiv. Length:	10	ft
Pipe Roughness:	0.0018	in
Number of Increments:	10	
Relief Device Liquid Kd:	0.707	
Relief Device Vapor Kd:	0.818	
Thermo Package:	Advanced_Peng-Robinson	
Nozzle Sizing:	API Numerical Integration	
Outlet Pipe Sizing:	Isothermal	

Notes:

Output Data:

Upstream Density:	1.99	lb/ft3
Upstream Z:	0.896	
Upstream Ideal Cp/Cv:	1.226	
Upstream Viscosity:	0.011	cP
Choked:	No	
Exit Pressure:	313.5	psig
Relief Device Kd:	0.818	
Relief Mass Flux:	732.2	lb/sec/ft2
Fanning Friction Factor:	0.006	

Pipe Flow Numerical Integration



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Composition:

Stream Description: Sigma HP Gas

Component	Mole Fraction
carbon dioxide	0.0048
nitrogen	0.0155
methane	0.7540
ethane	0.1279
propane	0.0623
isobutane	0.0053
butane	0.0184
isopentane	0.0031
pentane	0.0042
hexane	0.0015
heptane	0.0007
octane	0.0007
water	0.0015

Orifice Flow - Numerical Integration

LCV-3400 Bypass Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

The After Separator sends liquids to the Inlet Separator and has a design pressure of 1,440 psig and the maximum pressure is limited to 1,250 psig by the compressor 3rd stage discharge PSHH set points. As such, overpressure could occur in the event the bypass is inadvertently opened with subsequent gas blowby. Per field verification, the relief requirement is limited by RO-3400 with 3/8" ID. The upstream conditions were based on 1,250 psig and 120 F.

Note the liquid inventory in the After Scrubber is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.

Scenario Results Summary:

Required Rate:	6425.9	lb/hr	Device Choke Pressure:	125.4	psig
Actual Capacity:	78914.2	lb/hr	Outlet Temperature:	22.3	F
Required Area:	0.334	in2	Outlet Mass Quality:	1.000	
Actual Area:	4.08	in2	Outlet Density:	0.062	lb/ft3
Relief Pressure:	313.5	psig	Outlet Ideal Cp/Cv:	1.249	
Relief Temperature:	56.1	F	Outlet Viscosity:	0.010	cP
Relief Mass Quality:	0.987		Inlet Non-Recoverble dP:	2.8	psi
Relief Density:	1.42	lb/ft3	Inlet dP % Set:	1.0	% Set
Relief MW:	21.56		Built-Up Back Pressure:	21.3	psig
Relief Viscosity:	0.010	cP	Built-Up Back P % Set:	7.5	% Set
			Total Back Pressure:	21.3	psig
			Total Back P % Set:	7.5	% Set
			Reaction Force:	1052	lbf

Orifice Flow - Numerical Integration

LCV-3400 Bypass Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Input Data:

RO Tag:	RO-3400
Gas Type:	Dry Gas
Upstream Pressure:	1250 psig
Upstream Pressure Basis:	3rd Stage Discharge PSHH
Flash Type:	PT
Upstream Mass Quality:	1.000
Upstream Temperature:	120.0 F
Set Pressure:	285 psig
Allowable Overpressure:	10.00%
Constant Back Pressure:	0 psig
Pressure Increment:	10
Pipe ID:	1.939 in
Orifice ID:	0.375 in
Relief Device Liquid Kd:	0.707
Relief Device Vapor Kd:	0.818
Thermodynamic Package:	Advanced_Peng-Robinson
Nozzle Sizing:	API Numerical Integration Vapor
Outlet Pipe Sizing:	Isothermal

Notes:

--

Output Data:

Beta:	0.193
Orifice Flow C:	0.620
Discharge Cd:	0.620
Upstream Density:	5.67 lb/ft3
Upstream Z:	0.77
Upstream Ideal Cp/Cv:	1.23
Upstream Viscosity:	0.011 cP
Choked:	Yes
Exit Pressure (P2 for Sizing):	594.4 psig
Orifice Mass Flux:	2327.2 lb/sec/ft2
Required Mass Rate:	6,425.9 lb/hr
Relief Kd:	0.817
Relief Mass Flux:	769.6 lb/sec/ft2

Orifice Flow - Numerical Integration

LCV-3400 Bypass Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Composition:

Stream Description: Sigma Dry Gas

Component	Mole Fraction
carbon dioxide	0.0048
nitrogen	0.0155
methane	0.7553
ethane	0.1281
propane	0.0624
isobutane	0.0053
butane	0.0184
isopentane	0.0031
pentane	0.0042
hexane	0.0015
heptane	0.0007
octane	0.0007
nonane	0.0000
decane	0.0000
methanol	0.0000
water	0.0000
triethylene glycol	0.0000
	0.0000
	0.0000
	0.0000
	0.0000
	0.0000
	0.0000

External Fire Boiling Liquid API STD 521

V-1100 External Fire Water



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

The Inlet Separator may contain water that condenses out of the inlet stream. As such, overpressure could occur in the event of an external fire due to vaporization of the water. The fluid properties were based on the properties of pure water at the relief pressure of 344.9 psig (trace dissolved hydrocarbons were conservatively removed). The liquid level of 80% was based on the location of LSHH-1101 as estimated in the field.

Scenario Calculation Results:

Required Rate:	4756.1	lb/hr	Device Choke Pressure:	181.3	psig
Actual Capacity:	63360.7	lb/hr	Outlet Temperature:	325.0	F
Required Area:	0.306	in2	Outlet Mass Quality:	1.000	
Actual Area:	4.080	in2	Outlet Density:	0.032	lb/ft3
Relief Pressure:	344.9	psig	Outlet Ideal Cp/Cv:	1.304	
Relief Temperature:	434.3	F	Outlet Viscosity:	0.017	cP
Relief MW:	18.02		Inlet Non-Recoverble dP:	3.3	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	1.2	% Set
Relief Density:	0.78	lb/ft3	Built-Up Back Pressure:	25.6	psig
Relief SG:	0.621		Built-Up Back P % Set:	9.0	% Set
Relief Z:	0.87		Total Back Pressure:	25.6	psig
Relief Ideal Cp/Cv:	1.30		Total Back P % Set:	9.0	% Set
Relief Viscosity:	0.016	cP			

External Fire Boiling Liquid API STD 521

V-1100 External Fire Water



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Input Data:

Length:	<input type="text" value="20"/>	ft
Diameter:	<input type="text" value="66"/>	in
Orientation:	<input type="text" value="Horizontal"/>	
Head Type:	<input type="text" value="2:1 Ellipsoidal"/>	
Level Basis:	<input type="text" value="LSHH-1101"/>	
Additional Wetted Area:	<input type="text" value="9.8"/>	ft2
Level:	<input type="text" value="80%"/>	
Bottom Elevation:	<input type="text" value="3"/>	ft
Area Exponent:	<input type="text" value="0.82"/>	
Adequate Drainage	<input type="checkbox"/>	
Insulation Factor:	<input type="text" value="1"/>	
Start Mass % Vapor:	<input type="text" value="0.00%"/>	
Finish Mass % Vapor:	<input type="text" value="5.00%"/>	
Remove Sensible Heat:	<input checked="" type="checkbox"/>	Correct for Densities: <input type="checkbox"/>
Set Pressure:	<input type="text" value="285"/>	psig
Allowable Overpressure:	<input type="text" value="21.0%"/>	
Constant Back Pressure:	<input type="text" value="0"/>	psig
Use Thermodynamics:	<input checked="" type="checkbox"/>	
Thermo Package:	<input type="text" value="REFPROP 10.0"/>	
Relief Device Kd:	<input type="text" value="0.818"/>	
Nozzle Sizing:	<input type="text" value="API 520 Vapor"/>	
Outlet Pipe Sizing:	<input type="text" value="Isothermal"/>	

Notes:

Additional area accounts for boot which was estimated to be 18" OD x 2' S/S.

Scenario Output Data:

Wetted Area:	<input type="text" value="305.8"/>	ft2
Fire Heat Input:	<input type="text" value="3.77"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="791.9"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="0.0"/>	Btu/lb
Latent Heat:	<input type="text" value="791.9"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="434.3"/>	F
Temp. at Start Quality:	<input type="text" value="434.3"/>	F
Cp at Start Quality:	<input type="text" value="1.108"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="1.093"/>	Btu/lb/F
Liquid Density:	<input type="text" value="52.17"/>	lb/ft3
Required Mass Rate:	<input type="text" value="4756.1"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="2.40"/>	MMSCFD
Required Air Rate:	<input type="text" value="103544.7"/>	scfh air
Relief Mass Flux:	<input type="text" value="621.2"/>	lb/sec/ft2

V-1100 External Fire Water



Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Description: V-1100 Fire Water Vapor

[illegible]

Vapor Control Valve Failure: LCV-4100/4200

LCV-4100/4200 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

The Contactor scrubber section sends liquids to the Inlet Separator and has a design pressure of 1,440 psig and the maximum pressure is limited to 1,250 psig by the compressor 3rd stage discharge PSHH set points. As such, overpressure could occur in the event any of the level control valves were to fail open with subsequent gas blowby. The required relief rate was based on the normal gas composition at 1,250 psig and 120 F. Per field verification, LCV-4100 is a 1" Kimray 1400SMT PO with 1/4" linear trim and flow coefficients were obtained from vendor literature.

Note the liquid inventory in the 42" ID contactor is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.

Scenario Calculation Results:

Required Rate:	4,824.9 lb/hr	Device Choke Pressure:	125.4 psig
Actual Capacity:	77,426.1 lb/hr	Outlet Temperature:	44.3 F
Required Area:	0.255 in2	Outlet Mass Quality:	1.000
Actual Area:	4.08 in2	Outlet Density:	0.059 lb/ft3
Relief Pressure:	313.5 psig	Outlet Ideal Cp/Cv:	1.244
Relief Temperature:	75.2 F	Outlet Viscosity:	0.010 cP
Relief MW:	21.56	Inlet Non-Recoverble dP:	2.8 psi
Relief Mass Quality:	0.997	Inlet dP % Set:	1.0 % Set
Relief Density:	1.359 lb/ft3	Built-Up Back Pressure:	21.6 psig
Relief SG:	0.743	Built-Up Back P % Set:	7.6 % Set
Relief Z:	0.910	Total Back Pressure:	21.6 psig
Relief Ideal Cp/Cv:	1.237	Total Back P % Set:	7.6 % Set
Relief Viscosity:	0.010 cP	Reaction Force:	1058 lbf

Vapor Control Valve Failure: LCV-4100/4200

LCV-4100/4200 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Input Data:

Control Valve Tag:	LCV-4100/4200
Gas Type:	Inlet Gas
Upstream Pressure:	1250 psig
Upstream Pressure Basis:	3rd Stage Discharge PSHH
Upstream Temperature:	135 F
Dewpoint Vapor:	<input type="checkbox"/>
Set Pressure:	285 psig
Allowable Overpressure:	10.0%
Constant Back Pressure:	0 psig
Required Relief Rate Units:	lb/hr
Sizing Method	Kimray
Cv:	2.17
Xt (Cf for Kimray):	0.78
C1:	
Cg:	
Control Valve ID:	0.957 in
Inlet Pipe ID:	0.957 in
Outlet Pipe ID:	0.957 in
Additional Flow:	0.0 lb/hr
Use Thermo	<input checked="" type="checkbox"/>
Thermo Package:	Advanced_Peng-Robinson
Relief Device Kd:	0.818
Nozzle Sizing:	Numerical Integration
Outlet Pipe Sizing:	Adiabatic

Notes:

Scenario Output Data:

Fk:	0.82
K1 Inlet Piping Resistance:	0
K2 Outlet Piping Resistance:	0
K1 Inlet Piping Bernoulli:	0
K2 Outlet Piping Bernoulli:	0
Fp:	1
dP/P1 Actual:	0.740
dP/P1 Critical:	0.515
Y:	1.5
Upstream Density:	5.378 lb/ft3
Upstream Z:	0.794
Upstream Ideal Cp/Cv:	1.223
Control Valve Flow:	4,824.9 lb/hr
Required Mass Rate:	4,824.9 lb/hr
Required Rate Std Vol:	2.0 MMSCFD
Required Air Rate:	74,290.5 scfh air
Relief Mass Flux:	756.8 lb/sec/ft2

Vapor Control Valve Failure: LCV-4100/4200

LCV-4100/4200 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Composition:

Stream Description: Sigma Dry Gas

Component	Mole Fraction
carbon dioxide	0.0048
nitrogen	0.0155
methane	0.7553
ethane	0.1281
propane	0.0624
isobutane	0.0053
butane	0.0184
isopentane	0.0031
pentane	0.0042
hexane	0.0015
heptane	0.0007
octane	0.0007
nonane	0.0000
decane	0.0000
methanol	0.0000
water	0.0000
triethylene glycol	0.0000

LCV-4100

ITEM NUMBER
1200 SMT-P0
MAX. W.P. 4000
SER. NO. 2101810709

Vapor Control Valve Failure: LCV-3300/3301

LCV-3300/1 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Description:

The Inlet Filter Coalescer sends liquids from both chambers to the Inlet Separator and has a design pressure of 1,440 psig and the maximum pressure is limited to 1,250 psig by the compressor 3rd stage discharge PSHH set points. As such, overpressure could occur in the event either of the level control valves were to fail open with subsequent gas blowby. The required relief rate was based on the normal gas composition at 1,250 psig and 120 F. Per field verification, LCV-3300 and 3301 are both 1" Kimray 1400SMT PO with 3/8" linear trim and flow coefficients were obtained from vendor literature.

Note the liquid inventory in the Coalescer is minimal compared to the surge volume available in the Inlet Separator therefore no concerns are present with overfilling prior to gas blowby.

Scenario Calculation Results:

Required Rate:	4,886.9 lb/hr	Device Choke Pressure:	167.9 psig
Actual Capacity:	80,528.0 lb/hr	Outlet Temperature:	22.3 F
Required Area:	0.248 in2	Outlet Mass Quality:	1.000
Actual Area:	4.08 in2	Outlet Density:	0.062 lb/ft3
Relief Pressure:	313.5 psig	Outlet Ideal Cp/Cv:	1.249
Relief Temperature:	57.2 F	Outlet Viscosity:	0.009 cP
Relief MW:	21.56	Inlet Non-Recoverble dP:	2.9 psi
Relief Mass Quality:	0.987	Inlet dP % Set:	1.0 % Set
Relief Density:	1.419 lb/ft3	Built-Up Back Pressure:	22.1 psig
Relief SG:	0.743	Built-Up Back P % Set:	7.7 % Set
Relief Z:	0.899	Total Back Pressure:	22.1 psig
Relief Ideal Cp/Cv:	1.242	Total Back P % Set:	7.7 % Set
Relief Viscosity:	0.010 cP	Reaction Force:	1389 lbf

Vapor Control Valve Failure: LCV-3300/3301

LCV-3300/1 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Scenario Input Data:

Control Valve Tag:	LCV-3300/3301
Gas Type:	Inlet Gas
Upstream Pressure:	1250 psig
Upstream Pressure Basis:	3rd Stage Discharge PSHH
Upstream Temperature:	120 F
Dewpoint Vapor:	<input type="checkbox"/>
Set Pressure:	285 psig
Allowable Overpressure:	10.0%
Constant Back Pressure:	0 psig
Required Relief Rate Units:	lb/hr
Sizing Method	Kimray
Cv:	2.17
Xt (Cf for Kimray):	0.78
C1:	
Cg:	
Control Valve ID:	0.957 in
Inlet Pipe ID:	0.957 in
Outlet Pipe ID:	0.957 in
Additional Flow:	0.0 lb/hr
Use Thermo	<input checked="" type="checkbox"/>
Thermo Package:	Advanced_Peng-Robinson
Relief Device Kd:	0.818
Nozzle Sizing:	API 520 Vapor
Outlet Pipe Sizing:	Adiabatic

Notes:

Scenario Output Data:

Fk:	0.82
K1 Inlet Piping Resistance:	0
K2 Outlet Piping Resistance:	0
K1 Inlet Piping Bernoulli:	0
K2 Outlet Piping Bernoulli:	0
Fp:	1
dP/P1 Actual:	0.740
dP/P1 Critical:	0.515
Y:	1.5
Upstream Density:	5.674 lb/ft3
Upstream Z:	0.772
Upstream Ideal Cp/Cv:	1.226
Control Valve Flow:	4,886.9 lb/hr
Required Mass Rate:	4,886.9 lb/hr
Required Rate Std Vol:	2.1 MMSCFD
Required Air Rate:	73,966.6 scfh air
Relief Mass Flux:	789.5 lb/sec/ft2

Vapor Control Valve Failure: LCV-3300/3301

LCV-3300/1 Failure Open



Equipment Data:

Equipment Tag:	V-1100	Type:	Pressure Vessel
Drawing:	PID-1100	MAWP:	720 psig
Description:	Inlet Separator	MAWT:	120 F

Relief Stream Composition:

Stream Description: Sigma HP Gas

[illegible]

LCV-3301

KIMRAY
2220450243
MAX W.P 4000 PSI
1400 SMT PO 1/4"V CS NBR

WORD
Swag

Detailed Sizing: **API 520 Vapor**
PSV Tag Number: **PSV-1100**
Drawing: **PID-1100**
Sizing Scenario: **LCV-3400 Failure Open**



PSV Data:

Device Type:	Conventional	Orifice Designation:	M
Inlet NPS:	4"	Orifice Area:	4.08 in2
Inlet Schedule:	40	Set Pressure:	250.0 psig
Inlet Equivalent Length:	12.3 ft	Allowable Overpressure:	25%
Outlet NPS:	6"	Constant Backpressure:	0.0 psig
Outlet Schedule:	40	Kd	0.818
Outlet Equivalent Length:	12.1 ft	Kb	1.000
		Kc	1.000
		Device Sizing:	API 520 Vapor
		Outlet Pipe Sizing:	Adiabatic
		Thermo Package:	Advanced_Peng-Robinson

Scenario Data:

Required Rate:	61605.3 lb/hr	Relief Density:	1.422 lb/ft
Relief Mass Flux:	790.5 lb/ft2/sec	Relief Specific Gravity:	0.743
Relief Pressure:	313.5 psig	Relief Viscosity:	0.010 cP
Relief Temperature:	56.1 F	Outlet Temperature:	22.3 F
Relief MW:	21.56	Outlet Mass Quality:	1.000
Relief Z:	0.899	Outlet Density:	0.062 lb/ft
Relief Ideal Cp/Cv:	1.242	Outlet Viscosity:	0.009 cP
Relief Mass Quality:	0.987	Outlet Ideal Cp/Cv:	1.249

PSV Sizing Results:

Actual Capacity:	80613.7 lb/hr	Built-Up Back Pressure:	22.1 psi
Required Area:	3.118 in2	Built-Up Back P % of Set:	8.8%
Device Choke Pressure:	167.9 psig	Total Back Pressure:	22.1 psig
Inlet Pressure Drop:	2.9 psi	Total Back P % of Set:	8.8%
Inlet dP % of Set:	1.2%	Tail Pipe Exit Pressure:	10.7 psig
		Tail Pipe Exit Area:	28.890 in2
		Reaction Force:	1392.8 lbf

Detailed Sizing: **API 520 Vapor**
PSV Tag Number: **PSV-1100**
Drawing: **PID-1100**
Sizing Scenario: **LCV-3400 Failure Open**



Inlet Piping Pressure Drop Details

NPS	Sch	Fitting Type	Qty. or Length (ft)	Beta	EqL Actual NPS (ft)	EqL PSV Inlet NPS (ft)	Seg. dP (psi)	Exit P (psig)	Exit Vel. (fps)	Exit Mach
4"	40	Sharp Edged Entranc	1	0	10.25	10.25	2.44	311.1	178.1	0.15
4"	40	Ball Valve	1	0	1.01	1.01	0.24	310.8	178.1	0.15
4"	40	Pipe	1	0	1.00	1.00	0.24	310.6	178.1	0.15

Outlet Piping Pressure Drop Details

NPS	Sch	Fitting Type	Qty. or Length (ft)	Beta	EqL Actual NPS (ft)	EqL PSV Inlet NPS (ft)	Seg. dP (psi)	Exit P (psig)	Exit T (F)	Exit Vel. (fps)	Exit Mach
6"	40	Std. 90	1	0	7.08	7.08	4.2	17.9	24.8	917	0.78
6"	40	Pipe	5	0	5.00	5.00	17.9	10.7	24.1	1175	1

PSV-1100



1	Client:	RKR Engineering and Consulting	38	Manufacturer:	Mercer
2	Plant:	Gas Plant XYZ	39	Model Number:	91-71M11T1MNX1
3	Project:	Pressio 2024 Help Benchmarks	40	Project Number:	2024-1000
4	Service:	Inlet Separator	41	Serial Number:	1045480
5	P&ID Number:	PID-1100	42	Equipment Tag:	V-1100
GENERAL			PILOT		
6	Inlet:	4" Sch. 40 ANSI 300# RFWN	43	Pilot Type:	N/A
7	Outlet:	6" Sch. 40 ANSI 150# RFWN	44	Pilot Body:	N/A
8	Type:	Conventional	45	Pilot Trim:	N/A
9	BonnetType:	Closed	46	Pilot Seat:	N/A
10	NozzleType:	Semi	47	Pilot Tube:	N/A
MAIN BODY			48	Back Flow Preventer:	<input type="checkbox"/>
11	Body:	Carbon Steel	49	Supply Filter:	<input type="checkbox"/>
12	Nozzle:	Stainless Steel	SIZING BASIS		
13	Bonnet:	Carbon Steel	50	Code:	ASME VIII
14	Disc:	Stainless Steel	51	Stamp Required:	<input checked="" type="checkbox"/>
15	Trim:	Stainless Steel	52	Sizing Basis:	LCV-3400 Failure Open
16	Seat:	Viton	53	Relieves To:	Atmosphere
17	Spring:	Chrome Alloy	54	Certified Test	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> NB-18 Area and Kd
18	Bellows:	N/A	ACCESSORIES		
19			55	Cap:	Closed
20			56	Lifting Lever:	None
21			57	Test Ring	<input type="checkbox"/>
SELECTION					
22	Actual Capacity:	80,613.7 lb/hr	58	Orifice Designation (letter):	M
23	Required Capacity:	61,605.3 lb/hr	59	Discharge Coefficients, KdV/KdL:	0.818 / 0.650
24	Selected Orifice Area - in ² :	4.08	60	Backpressure Correction Kb:	1
25	Calculated Orifice Area - in ² :	3.118	61	Combination Capacity Factor (Kc):	1
FLUID DATA					
26	Operating Pressure:	146 psig	62	Operating Fluid:	Natural Gas
27	Installed Set Pressure:	250 psig	63	Operating Phase:	Vapor
28	Cold Differential Set Pressure:	250 psig	64	Relief Fluid:	Natural Gas
29	Allowable Overpressure:	25%	65	Relief Phase:	Vapor
30	Relief Pressure:	313.5 psig	66	Relief Mass Quality:	0.987
31	Operating Temperature:	267 F	67	Relief MW:	21.56
32	Relief Temperature:	56.1 F	68	Relief Z:	0.899
33	Outlet Temperature:	22.3 F	69	Relief Density:	1.422 lb/ft3
34	Inlet Pressure Drop:	2.9 psi 1.2 % of Set	70	Relief Viscosity:	0.010 cP
35	Constant Backpressure:	0.0 psig 0.0 % of Set	71	Relief cP/(Cp-R):	1.242
36	BuiltUp Backpressure:	22.1 psi 8.8 % of Set	72	Relief SG:	0.743
37	Total Backpressure:	22.1 psig 8.8 % of Set			
NOTES					
REVISIONS					
Rev.	Date	Description	By		
A	12/1/2024	Issued for Review	RAK		

MERCER VALVE COMPANY INC

6218 LONG DRIVE HOUSTON, TX. (713) 242-6960

VALVE REPAIR / TEST REPORT

JOB ORDER NUMBER:

COMPANY:

ADDRESS:

CUSTOMER CONTACT:

PO NUMBER:

DATE VALVE REPAIRED / TESTED: 6/10/2020

PLANT / BOOSTER			
UNIT #:			
LOCATION	1ST STAGE		
P.S.V. #:	1100		
MANUFACURER:	MERCER	CAP/BONNET	CLOSED
MFG. SERIAL NO.:	1045480	OUTLET SIZE/RATING:	6" 150RF
ORIFICE SIZE:	M	SEAT:	SOFT
INLET SIZE:	4" 300RF	CAPACITY	17723 SCFM
SET PRESSURE:	250	U.V. STAMPED:	YES
MODEL #:	91-71M11T1MNX1		
PRETEST INFORMATION			
1ST POP: 252		2ND POP: 251	
REMARKS: TEST ONLY - SEAL # FGS-218			
INSPECTION INFORMATION			
CAP:	OK	ADJUSTMENT:	N/A
BONNET:	OK	SCREW:	N/A
BODY:	OK	JAM NUT:	N/A
NOZZLE:	N/A	BLOWDOWN RING:	N/A
DISK:	N/A	SPRING:	N/A
		SPRING WASHERS:	N/A
SPRING DATA			
SPRING #:		COILS:	N/A
WIRE SIZE:	N/A	CONDITION:	N/A
PARTS REPLACED:			
NONE			
VALVE REPAIR AND TEST DATA			
SET PRESSURE:	250	TEST GUAGE:	100501
LEAK RATE:	LEAKAGE TIGHT @ 90% OF SET	MAINT SCHEDULE:	June - 20
TEST MEDIA:	NITROGEN	MENT MAINT. DATE:	June - 21
B.D.R.lower:	N/A	B.D.R. upper:	N/A
REPAIR TAG DATA			
SET PRESSURE:	250	QUALITY CONTROL INSP:	
REPAIR SERIAL #:	1304192	REPAIR TAG:	OK
DATE TESTED:	6/10/2020	SEAL WIRE:	OK
V.R. STAMPED:	NO	NAT GAS CAP:	
		CAPACITY	17723 SCFM

Office Number
1-800-833-6402

Webpage
www.mercervalue.net



Fax Number
405-495-8728

Email
sales@mercervalue.net

MERCER VALVE CO., INC.®
AUTO SEAT TECHNOLOGY®

PSV-1100

CERTIFICATE OF COMPLIANCE

Customer Name:

Customer PO Number: 5733299

Item Description: Qty: (1) 91-71M11T1MNX1

Series 9100

Set @ 250 psi

Capacity SCFM Air 17723

Repair Kit Number:

4" 300 RF X 6" 150 RF

Serial Number(s)

1095043

Customer PN

6M1T1NX4

Mercer Valve Sales Order Number: BS300

Mercer Valve Job Order Number: BS300-4

Valve Setting Instructions:

Set Pressure: 250 psi

Set Pressure Tolerance: 3%


Test Medium: Air

Leakage tight at 10% below set pressure


This certifies that the valves purchased on the above sales order number were built per section VIII, Division 1 of ASME boiler and pressure vessel code as indicated by the UV on the nameplate.

11/13/2014

Certified Individual
Quality Control



PSV-1100
4" x M x 6"
SET @ 250 PSIG





REFERENCE DRAWINGS								
NO.	TITLE							
		A	ISSUED FOR REVIEW	RAK			12/02/24	42
		NO.	REVISION	BY	CHK	APVD	DATE	

ENG. RECORD	DATE	GAS PLANT XYZ	
DRAWN BY RAK	12/02/24		
CHECKED			
APPROVED		JOB NO.	
APPROVED		DRAWING NO. PSV-1100	
SCALE			
		REV.	A

V-1100

NAT'L BRD 904

  CERTIFIED BY
VALERUS
Compression Services, LP

PT 1 M.A.W.P. 720 PSI at 120 °F

HT M.A.W.P. EXT PSI at °F

M.D.M.T. 6 °F at 720 PSI

MFG. SERIAL NUMBER NIP-1458 YEAR BUILT 2010


SO#


DWG # FGC 210300


● DESC. 66" ID X 20'


EST. WT. 30636 LBS


MFG: VALERUS











F-4100
HP GLYCOL FILTER

H-4110
1MM REBOILER
INTERNAL: ATMOS. @ -
EXTERNAL: - @ -
42" OD X 17'-0" LG
NON CODE
C.A.: NONE
N.D.E. TESTING: N/A

V-4120
FUEL GAS K.O. POT
INTERNAL: ATMOS. @ -
EXTERNAL: - @ -
XX" OD XX" LG
NON CODE
C.A.: NONE
N.D.E. TESTING: N/A

SK-4100
GLYCOL REGEN SKID
12'-2" x 29'-0"
1.0 MMBTU/HR
(VALERUS)

V-4130
PUMP GAS SEPARATOR
INTERNAL: 125 @ 250
EXTERNAL: - @ -
30" OD X 10'-0" LG
ASME SECTION VIII, DIV 1
C.A.: NONE
N.D.E. TESTING: RT-4

E-4160
GLYCOL/GLYCOL
EXCHANGER
EXTERNAL: - @ -
2" PIPE IN 4" PIPE
10 PASS, SPLIT 8/2


V-4140
CHARCOAL FILTER
INTERNAL: 15 @ 120
EXTERNAL: - @ -
12 3/4" OD X 4'-3" OAL
NON CODE
C.A.: NONE
N.D.E. TESTING: N/A

P-4171
GLYCOL PUMP
45015 PV
KIMRAY

P-4172
GLYCOL PUMP
45015 PV
KIMRAY

V-4150
GLYCOL SOCK FILTER
INTERNAL: 15 @ 120
EXTERNAL: - @ -
8 5/8" OD X 3'-9" S/S
NON CODE
C.A.: NONE
N.D.E. TESTING: N/A

CONNECTION SCHEDULE					
MK	QTY.	SIZE	RATING	TYPE	SERVICE
A	1	3"	3000#	NPT	VAPOR OUTLET
B	1	2"	S/80	NPT	REBOILER FILL
C	1	1 1/2"	3000#	NPT	GLYCOL INLET FROM ABSORBER
D	1	1 1/2"	3000#	NPT	GLYCOL OUTLET FROM ABSORBER
E	1	1"	3000#	NPT	REBOILER DRAIN
F	1	1"	3000#	NPT	GLYCOL DRAIN
G	1	1"	3000#	NPT	PGS DISTILLATE OUTLET
H	1	1"	3000#	NPT	PGS BACK PRESSURE OUTLET
J	1	1"	3000#	NPT	PGS DRAIN
K	1	3/4"	3000#	NPT	SUPPLY GAS INLET
L	1	1/2"	3000#	NPT	REBOILER SKIMMER
M	1	1/2"	3000#	NPT	FUEL GAS KO POT DRAIN
N	2	1/2"	3000#	NPT	SOCK FILTER DRAINS
P	1	1/2"	3000#	NPT	CHARCOAL FILTER DRAIN
Q	1	1"	3000#	NPT	GLYCOL RECOVERY



F-4200
HP GLYCOL FILTER

H-4210
1MM REBOILER
INTERNAL: ATMOS. @ -
EXTERNAL: - @ -
42" OD X 17'-0" LG
NON CODE
C.A.: NONE
N.D.E. TESTING: N/A

V-4220
FUEL GAS K.O. POT
INTERNAL: ATMOS. @ -
EXTERNAL: - @ -
XX" OD XX" LG
NON CODE
C.A.: NONE
N.D.E. TESTING: N/A

SK-4200
GLYCOL REGEN SKID
12'-2" x 29'-0"
1.0 MMBTU/HR
(VALERUS)

V-4230
PUMP GAS SEPARATOR
INTERNAL: 125 @ 250
EXTERNAL: - @ -
30" OD X 10'-0" LG
ASME SECTION VIII, DIV 1
C.A.: NONE
N.D.E. TESTING: RT-4

E-4260
GLYCOL/GLYCOL
EXCHANGER
EXTERNAL: - @ -
2" PIPE IN 4" PIPE
10 PASS, SPLIT 8/2

V-4240
CHARCOAL FILTER
INTERNAL: 15 @ 120
EXTERNAL: - @ -
12 3/4" OD X 4'-3" OAL
NON CODE
C.A.: NONE
N.D.E. TESTING: N/A

P-4271
GLYCOL PUMP
45015 PV
KIMRAY

P-4272
GLYCOL PUMP
45015 PV
KIMRAY

V-4250
GLYCOL SOCK FILTER
INTERNAL: 15 @ 120
EXTERNAL: - @ -
8 5/8" OD X 3'-9" S/S
NON CODE
C.A.: NONE
N.D.E. TESTING: N/A

CONNECTION SCHEDULE					
MK	QTY.	SIZE	RATING	TYPE	SERVICE
A	1	3"	3000#	NPT	VAPOR OUTLET
B	1	2"	S/80	NPT	REBOILER FILL
C	1	1 1/2"	3000#	NPT	GLYCOL INLET FROM ABSORBER
D	1	1 1/2"	3000#	NPT	GLYCOL OUTLET FROM ABSORBER
E	1	1"	3000#	NPT	REBOILER DRAIN
F	1	1"	3000#	NPT	GLYCOL DRAIN
G	1	1"	3000#	NPT	PGS DISTILLATE OUTLET
H	1	1"	3000#	NPT	PGS BACK PRESSURE OUTLET
J	1	1"	3000#	NPT	PGS DRAIN
K	1	3/4"	3000#	NPT	SUPPLY GAS INLET
L	1	1/2"	3000#	NPT	REBOILER SKIMMER
M	1	1/2"	3000#	NPT	FUEL GAS KO POT DRAIN
N	2	1/2"	3000#	NPT	SOCK FILTER DRAINS
P	1	1/2"	3000#	NPT	CHARCOAL FILTER DRAIN
Q	1	1"	3000#	NPT	GLYCOL RECOVERY

